

سم الله الرحمن الرحيم

مؤسسة مصبح بن عبدالله بن حمد السندي للتجارة
MUSABAH ABDULLAH HAMED ALSANIDI TRD



Certificate of Analysis

Customer Name; Indian School J.B.B.A

Production Date; 20-9-2024

Expiry Date ; 19-9-2025

Sample Type; Bottled Drinking Water

Temperature On Receipt *C 25

Analysis Started Date; 20-9-2024

Analysis Finished Date; 23-9-2024

ANALYTICAL RESULTS

Bacteria analysis

Frequency: Monthly

Parameter	Standard	Result	Remarks
Total Coliform	25colony/1ml	<u>Absent</u>	<u>Ok</u>
E.Coli	0 colony/100ml	<u>Absent</u>	<u>Ok</u>
p-Seudamonas	0colony/250ml	<u>Absent</u>	<u>ok</u>

Frequency: Daily

Parameter	Standard	Result	Remarks
Apperance	Clear	OK	
Odour	No offensive	OK	
Taste	Agreeable	OK	
TDS	100-500 mg/L	109	
PH	6.5 – 8.5	7.1	
Total Alkalinity	≤250mg/L	30	
Total Hardness	≤200mg/L	30	
Calcium	≤150 mg/L	5.34	



[Handwritten signature]

Magnesium	≤50mg/L	4	
chloride	≤200mg/L	27.4	
Potassium	≤200mg/l	9.76	
OZONE	≤200mg/l	00.04	

REMARKS: Sample has passed as per UN bottled drinking water OS8/2012.

VALIED ONLY FOR ANALYSED PARAMETERS.



Chemist: BINU RAVI